II & Final bill

M.A.R. 57 (Rule 116)

Measurement Book No. A/10 120359

Serial No. Shifting & Electrical utilities & Road widening from NH-7 to SWD Bridge along Jakkur Road Near Rajthara

Name of work. From To

Name of Contractor of nature of Agency. Sathya Constructions.

Date of commencement of work. GC(Project) +NG 20Ne/wo/01/16-17 Dt-9/6/16

Date	Full description, etc, of work	Dimensions				Contents	Reference to last Measurement
		Number	Length	Breadth	Depth		
1	2	3	4	5	6	7	8
1)	Units Pumpole		2 Nos		15800/-	-6-	31600/-
2)	9 mts long RCC Pole		2 Nos		5800/-	-6-	11600/-
3)	Horizontal X Arm set with HTST support. Bolts nuts washers & pole clamping.		5 Nos		430/-	-6-	2150/-
4)	4 core X arm		5 Nos		310/-	-6-	1550/-
5)	11 KV Pin Insulator		12 Nos		103/-	-6-	1236/-
6)	45 KN Disc Insulator		6 Nos		300/-	-6-	1800/-
7)	11 KV Pin Insulator		15 Nos		41/-	-6-	615/-
8)	70 KN Strain Insulator		10 Nos		140/-	-6-	1400/-

M.A.R. 57 (Rule 116)

Measurement Book

No. A/10 120365

Serial No.....

Name of work.....From.....To.....

Name of Contractor of nature of Agency.....

Date of commencement of work.....

Date	Full description, etc, of work	Dimensions				Contents	Reference to last Measurement
		Number	Length	Breadth	Depth		
1	2	3	4	5	6	7	8
52)	Natural Corporate Zinc (IS 2062) SL No 162 Cubicle 7(2		Arch Plate fg.				
53)	natural copper steel		4 wire rope storm		1601	4	6400
54	Supplying high pressure sodium vapour flood light luminaire 2 row futtab for use with high pressure sodium vapour lamp with integrated control gear tray cable boards heater tube drawn wire conductor metric two cpt all wiring with Lab facility and test all wiring		40		35f	Pkg	14000/-

E.E. (Electrical)

MEASUREMENT BOOK

Date	Full description, etc, of work	Dimensions				Contents	Reference to last Measurement
		Number	Length	Breadth	Depth		
1	2	3	4	5	6	7	8
	Cable GI DM Armoured suitable for outdoor Dia of location to Room cable entry through a cable gland with suitable cable lug for protection to both electrical & electrical equipment. Bottom cover rope be with poly carbonate Hinged trusted gland Insulation Electrical Resistance >20 M. and ambient Temp > 30 deg C High discharge Electro magnetic hallast with capacitor and choke cycle Energy Saving Lamp to Waterproof dual coated copper wire conforming to IEC 61347-2-9 safety & IEC 60923-Ballast Energy type Temperature shall be suitable to operate on 230/240V 50 Hz supply mains including, gaskets, Cable lugs & tagging terminal Ring cable gland 2 Nos with gland SA.						

E.E. (Electrical)

M.A.R. 57 (Rule 116)

Measurement Book

No. A/10 120367

Serial No.....

Name of work.....From.....To.....

Name of Contractor of nature of Agency.....

Date of commencement of work.....

Date	Full description, etc, of work	Dimensions				Contents	Reference to last Measurement
		Number	Length	Breadth	Depth		
1	2	3	4	5	6	7	8
	a) 100-125A.		5	Nos	453006	765001-	
					Total Qty	614176-92	
	Details of 250 KVA Transformers						
1)	New Pole 01 Coradam School road Cotteeswaram to Venkatala						
2)	New Pole 02 Coradam School Road Cotteeswaram to Venkatala						
3)	New pole 3 Coradam School Road Cotteeswaram to Venkatala						
4)	New Pole 4 Coradam School Road Cotteeswaram to Venkatala						

Assistant Executive Engineer (Ele)
BBMK Bandalanka

MEASUREMENT BOOK

Date	Full description, etc, of work	Dimensions				Contents	Reference to last Measurement
		Number	Length	Breadth	Depth		
1	2	3	4	5	6	7	8
	Certificate:- Certify that the work has been carried out satisfactorily. R. T. Ravi (EE)						
	Bill = 6,14,177=00						
	IT 1% 6142=00						
	SGST 1% 6142=00						
	CGST 1% 6142=00						
	LWC 1% 6142=00						
	CBF 0.1% 614=00						
	deduction 25,182=00						
	cheque = 5,88,995=00						
					Assistant Executive Engineer (Ele) BBMP, Bangalore		
					ಲೆಕ್ಕಶೀರ್ಷಿಕೆ ...p2786 winding and Stranding... ರೂ:6,14,177=00 ... ಪಾವತಿ ಸ್ವೀಕರಿಸಿದೆ ರೂ:5,88,995=00 ... ಪಾವತಿಯಾಗಿದೆ ರೂ:25,182=00 ... ಕಡಿತ ಮಾಡಿದೆ		
					ಲೆಕ್ಕ ಅಧೀಕ್ಷಕರು ಕಾ.ಪಾ.ಅ.(ಬಿ) ಯಲಹಂಕ ವಲಯ		